

Contaminant Abbreviation	Contaminant	UCMR Minimum Reporting Level (MRL, µg/L)	Regulatory Level (µg/L)	Non-Regulatory Health-Based Reference Concentration (Ref Conc, µg/L)	Health-Based Reference Dose (RfD) (mg/kg-day)	Reference	Second Reference
lithium	lithium	9		Health Reference Level = 10	Subchronic and Chronic Provisional RfD = 2e-3	Technical Support Document for the Final CCL 5 - Contaminant Information Sheets	
PFOS	perfluorooctanesulfonic acid	0.004	0.0040			2024 Final PFAS NPDWR	
PFOA	perfluorooctanoic acid	0.004	0.0040			2024 Final PFAS NPDWR	
HFPO-DA	hexafluoropropylene oxide dimer acid (GenX chemicals)	0.005	0.01			2024 Final PFAS NPDWR	
PFHXS	perfluorohexanesulfonic acid	0.003	0.01			2024 Final PFAS NPDWR	
PFNA	perfluorononanoic acid	0.004	0.01			2024 Final PFAS NPDWR	
PFBS	perfluorobutanesulfonic acid	0.003				2024 Final PFAS NPDWR	
PFBA	perfluorobutanoic acid	0.005		Health-Based Screening Level = 6	Chronic RfD = 1e-3; Subchronic RfD = 6e-3	2024 USGS HBSL (based on 2022 IRIS Assessment)	2022 IRIS Assessment
PFHxA	perfluorohexanoic acid	0.003		Health-Based Screening Level = 3	Subchronic and Chronic RfD = 5e-4	2024 USGS HBSL (based on 2023 IRIS Assessment)	2023 IRIS Assessment
PFDA	perfluorodecanoic acid	0.003			Subchronic and Chronic RfD = 2e-9	2024 IRIS Assessment	
11CI-PF3OUdS	11-chloroicosaffluoro-3-oxaundecane-1-sulfonic acid	0.005					
8:2 FTS	1H, 1H, 2H, 2H-perfluorodecane sulfonic acid	0.005					
4:2 FTS	1H, 1H, 2H, 2H-perfluorohexane sulfonic acid	0.003					
6:2 FTS	1H, 1H, 2H, 2H-perfluorooctane sulfonic acid	0.005					
ADONA	4,8-dioxa-3H-perfluorononanoic acid	0.003					
9CI-PF3ONS	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid	0.002					
NFDHA	nonafluoro-3,6-dioxaheptanoic acid	0.02					
PFEESA	perfluoro (2-ethoxyethane) sulfonic acid	0.003					
PFMPA	perfluoro-3-methoxypropanoic acid	0.004					
PFMBA	perfluoro-4-methoxybutanoic acid	0.003					
PFDoA	perfluorododecanoic acid	0.003					
PFHpS	perfluoroheptanesulfonic acid	0.003					
PFHpA	perfluoroheptanoic acid	0.003					
PFPeS	perfluoropentanesulfonic acid	0.004					
PFPeA	perfluoropentanoic acid	0.003					
PFUnA	perfluoroundecanoic acid	0.002					
NEtFOSAA	n-ethyl perfluorooctanesulfonamidoacetic acid	0.005					
NMeFOSAA	n-methyl perfluorooctanesulfonamidoacetic acid	0.006					
PFTA	perfluorotetradecanoic acid	0.008					
PFTrDA	perfluorotridecanoic acid	0.007					

Selections:	PWS: IL0312250 - OAK PARK, IL State: IL										
	UCMR Minimum Reporting Level (MRL, µg/L)	Non-Regulatory Health-Based Ref Conc (µg/L)	Total Results	Results ≥ MRL	Results > Health-Based Ref Conc	Percent of Results > Health-Based Ref Conc	Total PWSs with Results	PWSs with Results ≥ MRL	PWSs with Results > Health-Based Ref Conc	Percent of Large PWSs with Results > Health-Based Ref Conc	Percent of Small PWSs with Results > Health-Based Ref Conc
lithium	9	10	4	0	0	0.0%	1	0	0	0.0%	-
PFBA	0.005	6	4	0	0	0.0%	1	0	0	0.0%	-
PFHxA	0.003	3	4	0	0	0.0%	1	0	0	0.0%	-
PFDA	0.003	-	4	0	-	-	1	0	-	-	-
11CI-PF3OUds	0.005	-	4	0	-	-	1	0	-	-	-
8:2 FTS	0.005	-	4	0	-	-	1	0	-	-	-
4:2 FTS	0.003	-	4	0	-	-	1	0	-	-	-
6:2 FTS	0.005	-	4	0	-	-	1	0	-	-	-
ADONA	0.003	-	4	0	-	-	1	0	-	-	-
9CI-PF3ONS	0.002	-	4	0	-	-	1	0	-	-	-
NFDHA	0.02	-	4	0	-	-	1	0	-	-	-
PFEESA	0.003	-	4	0	-	-	1	0	-	-	-
PFMPA	0.004	-	4	0	-	-	1	0	-	-	-
PFMBA	0.003	-	4	0	-	-	1	0	-	-	-
PFDoA	0.003	-	4	0	-	-	1	0	-	-	-
PFHpS	0.003	-	4	0	-	-	1	0	-	-	-
PFHpA	0.003	-	4	0	-	-	1	0	-	-	-
PFPeS	0.004	-	4	0	-	-	1	0	-	-	-
PFPeA	0.003	-	4	0	-	-	1	0	-	-	-
PFUnA	0.002	-	4	0	-	-	1	0	-	-	-
NEtFOSAA	0.005	-	4	0	-	-	1	0	-	-	-
NMeFOSAA	0.006	-	4	0	-	-	1	0	-	-	-
PFTA	0.008	-	4	0	-	-	1	0	-	-	-
PFTrDA	0.007	-	4	0	-	-	1	0	-	-	-