



Electric Vehicle Charging Systems Guideline

A permit is required, Submit a completed application along with, a plat of survey, site plan, manufactures' installation instructions, and the licensed / registered contractors' information electronically at www.oak-park.us .

GENERAL NATIONAL ELECTRIC CODE REGULATIONS:

- Refer to the adopted National Electric Code for details.
- Provide the general information such as the manufacture's installation instructions which may include: (The entire manufactured system shall be listed and labeled.)
- Provide a complete electrical power plan indicating location of all proposed electrical. Provide the electrical calculations of the services panel.)
- Provide a floor plan on the proposed location.
- Provide details on the Equipment construction such as the grounding pole, ventilation, markings, and cables. The grounded system shall be GFCI protected, the Faulted Circuits shall be isolated, and markings and or warning label(s) are required.
- Provide a detailed site plan if located outside.
-

VILLAGE OF OAK PARK GENERAL ZONING REGULATIONS (-Article 103 (i))

1. Commercial electric vehicle charging stations are permitted as an accessory use within any parking lot, parking structure in all districts.
2. Electric charging station equipment may not block the public right-of-way.
3. Each public charging station space must be posted with a sign indicating the space is only for electric vehicle charging purposes. Days and hour of operations must be included if time limits of tow away provisions are to be enforced by the owner. Information identifying voltage and amperage levels or safety information must be posted.
4. Charging station equipment must be maintained in good condition and all equipment must be functional. Charging stations no longer in use must be immediately removed.

STATE OF ILLINOIS NOTIFICATION

- The installer shall notify the State of Illinois of the installation and register with the utility

Note: This guideline is not all inclusive of the related codes and laws that pertain to this construction refer to the actual code book for details. The permit process is a check and balance system that normally involves a designer, plans examiner, contractor, and inspector to ensure the best quality and safest construction possible. As much as the mentioned professionals attempt to achieve full code compliance every effort has been made to identify all code deficiencies however; failure to identify a code deficiency during plan review and inspection does not alleviate any obligation to comply with all applicable code provisions.

VILLAGE OF OAK PARK & STATE OF ILLINOIS REQUIREMENTS

RESIDENTIAL

- A building shall contain at least one level 2 electric vehicle charging station at one parking location if a building contains a parking space/garage (VOP)
- SINGLE FAMILY and SMALL multi-family residential (2-4) to have one EV capable parking space per unit for designated parking (ILLINOIS).

COMMERCIAL / MULTIFAMILY

- A minimum of one level 2 electric vehicle charging station at each onsite parking area shall be installed for every 5 parking spaces. One charging station may serve an adjacent pair of spaces (VOP)
- 03/31/24 (90 days after effective day) building permits for new LARGE (5 or more families) multi-family residential to have 100 % parking EV capable(ILLINOIS).
- 3/31/24 building permits for large residential buildings being RENOVATED by developer* to be CONVERTED to CONDOS to have 100% parking EV capable *exemption if would entail excavating existing parking lot or facility (ILLINOIS).

Affordable Housing*

- Jan 2024 – Building Permits Require 40% compliance.
- Jan 2028 – Building Permits Require 50% compliance.
- Jan 2032 – Building Permits Require 70% compliance.

**Exempt if local zoning code does not require EVC parking spots*

The new law pertains to new residential and multi-family construction except if large residential unit buildings are being converted to condos. Commercial buildings were left out.

To view the full Illinois text go to <https://www.ilga.gov/legislation/publicacts/fulltext.asp?Name=103-0053&print=true&write=>

ROUGH & FINAL INSPECTIONS REQUIRED

- A rough and final inspection is required
-

TO PURCHASE CODE BOOKS, CONTACT THE INTERNATIONAL CODE COUNCIL AT: 800-214-4321 www.intlcode.org

IN EMERGENCY CALL:

Police/Fire @911 NICOR@ 888-642-6748 Com Ed@ 800-344-7661 J.U.L.I.E. 811

In general, nothing should be concealed unless a passing inspection has been issued.

TO SCHEDULE AN INSPECTION e-mail at permits@oak-park.us or CALL 708-358-5430